



Capitol Cement
11551 Nacogdoches Rd.
San Antonio, TX 78217

Masonry Cement S - C 91

Date: March 10, 2026

Production Period:

Beginning February 1, 2026

Ending February 28, 2026

PHYSICAL

| Item | Spec. Limit | Test Result |
|----------------------------------|-----------------------------|-------------|
| Air Content of Mortar (volume %) | 8.0 minimum 19.0 maximum | <u>14</u> |
| 325 % retained | 24 maximum | <u>0.90</u> |
| Water Retention (%) | 70 minimum | <u>92</u> |
| Time of setting (minutes) | | |
| Gilmore | | |
| Initial | Not less than 90 | <u>285</u> |
| Final | Not more than 1000 | <u>390</u> |
| Compressive Strength | | |
| 7 Day (psi) | 1300 minimum | <u>2410</u> |
| 28 Day (psi) (Jan) | 2100 minimum | <u>3010</u> |

We certify that the above cement, at the time of shipment meets the chemical and physical requirements of the current ASTM C 91 specifications. The above data represents the averages of representative samples from production.



Violeta Vega-Gomez, Quality Control Manager